

TEST REPORT

PL/FOR/016/01

ULR Number	TC882822000000634F		
Sample Number	PL/W/22-23/0850	Report Date	19 October 2022
Customer details	Edify School #226/227, 25th Mile, Kanakapura Road, Somanahalli, Bengaluru - 560116		
Sample Details	Filtered Water		
Sample Condition	Good	Sample Received date	14 October 2022
Sample Package	NA	Analysis Started on	14 October 2022
Sample provided by	Customer	Analysis Ended on	19 October 2022

Sl. No.	Parameters	Test method	Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Odour	IS : 3025 (part 5)	Agreeable	Agreeable
2	Turbidity	IS : 3025 (part 10)	<0.5	Maximum 1 NTU
3	pH Value	IS : 3025 (part 11)	6.8	6.5 – 8.5
4	Total Dissolved Solids	IS : 3025 (part 16)	31	Maximum 500 mg/L
5	Total Hardness as CaCO ₃	IS : 3025 (part 21)	8	Maximum 200 mg/L
6	Calcium as Ca	IS : 3025 (part 40)	2	Maximum 75 mg/L
7	Magnesium as Mg	IS : 3025 (part 46)	<1	Maximum 30 mg/L
8	Chloride as Cl	IS : 3025 (part 42)	16	Maximum 250 mg/L
9	Total Alkalinity as CaCO ₃	IS : 3025 (part 23)	40	Maximum 200 mg/L
10	Sulphates as SO ₄	IS : 3025 (part 24)	<1	Maximum 200 mg/L
11	Fluoride as F	IS : 3025 (part 60)	0.1	Maximum 1 mg/L
12	Iron as Fe	IS : 3025 (part 53)	<0.1	Maximum 1 mg/L
13	Total Coliform bacteria	IS : 15185 : 2016	Absent	Shall not be detectable in 100 mL sample
	E Coli	IS : 15185 : 2016	Absent	

Inference: The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

Note:

1. The results listed refer only to the tested sample and applicable parameters.
2. In case of dispute our liability is limited to the billed amount received by us.
3. Samples will be preserved for 15 days on request. Food samples and microbiology samples will be discarded after analysis.
4. This certificate shall not be reproduced except full without approval of the laboratory and cannot be used as evidence in the court of law.

For VASAVI VIDYANIKETHAN TRUST

[Signature]
Secretary General

[Signature]
Authorized Signatory

Suprita Behera
Senior Associate- Prewel Labs
Microbiology




[Signature]

Principal in-Charge
Edify School Bengaluru.
(A Unit of VVN Trust)

#226/227, Somanahalli, Kanakapura Main Road,
Page No: 01 of 01 082.

[Signature]
Authorized Signatory

Mahadeva M J
Assistant Manager- Prewel Labs
Chemistry



+91 63669 42390

CIN : U85300KA2021PTC147708 | support@prewellabs.com

#24, 22nd Main, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078