OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka Fire & Emergency Services,
Anjanapura Fire Station,
BENGALURU - 560 108.



Office of the District Fire Officer, Karnataka Fire & Emergency Services, Anjanapura Fire Station, Bengaluru.



No. 11/DFO/AFS/BLR/RCC/2023

Dated: 03-03-2023.

"Annexure-2"

To,

The Authorized Signatory, Edify School, Sy. No 226/227, Somanahalli, Kanakapura Main Road, Bengaluru,

Sir.

Sub: Issue of "Renewal Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. Edify School. Sy. No. 226/227, Somanahalli, Kanakapura Main road, Bengaluru"-reg.

Ref: 1) CFO (w) office FSR No. 894/CFO/BWZ/FSR/2021, D: 27-12-2021 2) CFO (W) office FSCR No. 849/CFO/BWZ/FSCR/2021, D: 31-12-2021.

3) Your request letter dated: 25-02-2023,

4) Inspection report no: 120/FSO/AFS/Bng-2023; dated: 28-02-2023.

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. Edify School, Sy. No. 226/227, Somanahalli, Kanakapura Main road, Bengaluru" with a condition to fulfill the recommendations and compliance the same within 3 months and as per ref (2), the Fire Safety Compliance Report was issued for the same.

With reference cited (3) above, the management of 'Edify School' had requested for the renewal fire safety compliance report from our department. In this regard the above school building was inspected by Fire Station Officer, Anjanapura Fire Station, Bengaluru on 27-02-2023 and cited in (4) reference above submitted the Fire Safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "M/s. Edify School, Sy. No. 226/227, Somanahalli, Kanakapura Main road, Bengaluru." Subject to proper maintenance of firefighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report.

"This report is valid for only one year from the date of issue and is renewable without fail'.



Pours falthfully,

HER DISTRICT FIRE OFFICER

Anjanapura Fire Station,

BENGALURU - 560 108.



FIRE PROTECTION SYSTEMS CORPORATION

Manufacturers, Engineers and Contractors FIRE FIGHTING EQUIPMENTS OF ALL TYPES Ph: 080 2660 3673, Mob: +91 98860 19240.

Ref: OGN/EDIFY/2024-TC

Date: 18.03.2024

TEST AND GUARANTEE CERTIFICATE TO WHOMSOEVER IT MAY CONCERN

We Certify, that, Fire Extinguishers belonging to M/s. Edify School, Kanakapura Main Road, Somanahalli, Bengaluru: 560 062, that is, Dry Chemical Powder Stored Pressure ABC type Fire Extinguishers, 4 kgs. capacity x 10 Nos. have been tested to an internal hydraulic pressure of 25 kgs/cm2 and 5 kgs. capacity x 6 Nos. have been tested to an internal hydraulic pressure of 30 kgs/cm2, CO2 type 2 Kgs. capacity have been tested to an internal hydraulic pressure of 236 Kgf/cm2, all the Fire Extinguishers are duly serviced and recharged, after which, all Fire Extinguishers are in perfect working condition and are also guaranteed against any leakage for period of one year from the date of our invoice, subject to proper storage, handling and maintenance at party's premises.

for FIRE PROTECTION SYSTEMS CORPORATION

COMMERCIAL MANAGER.

20/3/24

Sales Office: C/o. Jayaprakash Rao, 004, Ground Floor, Sovereign Park Apartment 56/58, K.R. Road, Basavanagudi, Bangalore - 560 004. E-mail: ocb.fpsc@gmail.com